

Ref.No. KKG/KPM/PBSC/020

Date 12/11/2021

STATEMENT ACCOMPANYING FORM - A

1. Name of the Building Sri Ragavendra Public School(CBSE)
Door Number of the Building --
2. Location (Street Number, ward Number, Name of Place, i.e., Corporation/Municipality/Township/Contonment Survey Ward :C, Block:21, T.S.No: 9/28, 9/1A, 9/29-pt & 9/1B-pt, Komarapalayam Agraharam Village & Municipal Limit, Pallipalayam Main Road, Komarapalayam Komarapalayam Taluk,Namakkal District .
3. Year of Construction 2008
4. Approximate cost of construction as per current rate Rs.3,00,00,000.00
5. Purpose for which the building is being used or Proposed to be used School Building
6. Purpose for which the building has either to been used School Building
7. Details for construction of the building (Particulars of the foundation soil. Specification of the various parts under
- | | | |
|---------------------|---|--|
| i) Foundation | : | R.C.C. Column Footing & R.R.Masonry in Cement Mortar |
| ii) Basement | : | R.C.C. Plinth Beam & R.R.Masonry in Cement Mortar |
| iii) Superstructure | : | R.R.C.C.Column with Brick Work in Cement Mortar |
| iv) Floor and Roof | : | R.C.C. Flat roof with Cement Mortar Flooring |
8. Period for which license is required effect from 31/01/2022 to 30/01/2025
9. Carpet Area of the building 12381.12 sft
- 10.No. of persons to be accomodated (including all) 1235 Nos.

Date: 12/11/2021

Signature of the Engineer

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or it portion of the building originally is changed or altered sub-sequently.

Date : 12/11/2021

Signature of the owner of the building

CHAIRMAN
Sri Ragavendra Educational Trust
& Komarapalayam - 639 143.
Namakkal District

FORM - B

(Form of certificate of Structural Soundness Under-section (4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features : -

(1) Foundation :

- | | | |
|---|---|-------------|
| i. Depth below ground level | : | 2.44 M |
| ii. Nature of soil met with at foundation level | : | Hard Moorum |
| iii. Pressure at foundation | : | 40 T/Sqm |
| iv. Probable safe bearing capacity of the strata met with at foundation | : | 50 T/Sqm |

(2) Superstructure :


- | | | |
|--|---|---|
| i. Maximum stress in the most critical section of masonry and concrete | : | Masonry - 40 T/Sqm
Concrete - 400 kg/Sqm |
| ii. Nature of masonry and concrete and safe premissible stress | : | Masonry - 50T/Sqm
Concrete - 450 kg/Sqm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period of **3 Years**

effect from 31/01/2022 to 30/01/2025

Date **12/11/2021**

Signature of the Engineer
District Panel Engineer Class - 1A



ANNEXURE TO FORM -B
STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS


Location of the Building D.No., St., and build.of the place	Survey Ward :C, Block:21, T.S.No: 9/28, 9/1A, 9/29-pt & 9/1B-pt, Komarapalayam Agraharam Village & Municipal Limit, Pallipalayam Main Road, Komarapalayam Komarapalayam Taluk, Namakkal District .
Age of the building	13 Years
Number of Storeys	Upto Second Floor
Short description of structure- steel R.C.C. Framed of load bearing masonry	RCC Framed Structure
Purpose for which the building is Certified for use sound	School Building
The period forwhich the building will be structurally sound with	effect from <u>31/01/2022</u> to <u>30/01/2025</u>
No. of persons to be accomadated(including all)	1235 Nos

**THIS CERTIFICATE WILL NOT HOLD GOOD IN TIMES OF NATURAL CALAMITIES
LIKE FIRE, FLOOD AND EARTH QUAKE ETC.**

1. This Stability Certificate contains 10 pages including Erode District Class-I A & Namakkal District Panel engineer certificate copy & 2 Nos of Blue prints which are Prepared by me, With Ref No.SBBP & E/KPM/STB-PLAN/022, Date: 01/02/2019.
- 2.Any construction and alteration activities should not be carried out on the working hours & days.
- 3.Periodical Maintance should be carried out regularly.
- 4.Permanet Structures (having roof) are only covered in this stability certificate.
5. No approval plan Produced for my perusal.

Date : 12/11/2021

Er.K.KUMARAGURUPARAN
District Panel Engineer Class - 1A



FORM - C

(Form of certificate of Structural Soundness Under-section (4) of section 4 of the Madras Public Buildings (Licensing) Act, 1965 (Madras Act 13 of 1965), referred to in rule 4 of the Madras Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features : -

(1) Foundation :

- | | | |
|---|---|-------------|
| i. Depth below ground level | : | 2.44 M |
| ii. Nature of soil met with at foundation level | : | Hard Moorum |
| iii. Pressure at foundation | : | 40 T/Sqm |
| iv. Probable safe bearing capacity of the strata met with at foundation | : | 50 T/Sqm |


(2) Superstructure

- | | | |
|--|---|---|
| i. Maximum stress in the most critical section of masonry and concrete | : | Masonry - 40 T/Sqm
Concrete - 400 kg/Sqm |
| ii. Nature of masonry and concrete and safe premissible stress | : | Masonry - 50T/Sqm
Concrete - 450 kg/Sqm |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (Latest version) and other relevant indian standards code of Practice and I declare that the building is structurally sound to be used as public building for the purpose noted in the statement. A licence may granted for the period o **3 Years** effect from **31/01/2022** to **30/01/2025**

Date : **12/11/2021**

Signature of the Engineer
District Panel Engineer Class - 1A



DECLARATION

I, K.KUMARAGURUPARAN, son of Sri.K.K.A.Kandasamy, 32, Sivagnanam Street, Opp. to Kamatchi Kalyana Mandapam, Bhavani - 638 301, do hereby declare that I possess the qualification experience specified in the fable to rule II of the Tamilnadu public buildings (Licensing) Rules, 1966 for issuing the certificate of structural soundness of the building covered by the certificate. Also under the G.O. MS No. 97 Municipal Administration and Water Supply (M.A.4) Department Dated 16.07.2001

- 1) This Report does not include any eventualities caused due to natural calamities
- 2) we hereby advice that periodical repairs and renovations shall be carried out to the entire building blocks regularly by every year and intimating me through writing
- 3) Further necessary fire fighting equipments should be kept in the premises and should be trained for for operation. If any fire accident/mishap occurs we are not held responsible.
- 4) Emergency exit to be provided as per norms
- 5) All electrical points, wiring/Gadgets has to checked properly and to be maintained periodically. For this, competent engineer is not held responsible for electrical defaults.
- 6) If any violation is found at a later stage after issue of this report, we are not held responsible and this report gets cancelled.
- 7) Further, this report covers the certification for the particular blocks, Floors only mentioned in the Plan - Legal aspects are not considered.

DISTRICT PANEL ENGINEER FOR :

Erode District Panel Engineer Class I-A
(R.Dis.No:25659/2007 C2)

Namakkal District Panel Engineer Class I
(R.Dis : 6073/99)

Station : **KOMARAPALAYAM**

Date : **12/11/2021**

SIGNATURE OF THE CERTIFYING ENGINEER



PRESENT: THIRU. DAYANAND KATARIA, I.A.S.,

R.Dis.6073/99 (C2)

Dated: 11.11.99.

Sub: Tamil Nadu Public Buildings (Licensing) Act, 1965 -
Namakkal District - Drawing of Panel of
Registered Engineers under rule - Inclusion of
the name of Thiru K. Kumarakurubaran in the Panel
of Private Practising Engineers under Class I
Category in Namakkal District.

- Ref: 1. Application of Thiru K. Kumarakurubaran,
dated 5.2.99.
2. Chief Superintending Engineer (PWD) Buildings
(C&M) Salem, letter No. 554 M/F73/99 VA 6,
dated 21.7.99.
3. Engineer in Chief W.R.O. & Chief Engineer (General)
P.W.D. letter No. AEE/T1/JE/36464/97, dt. 30.8.99.
4. Board of Engineer's proceedings 371/18-98,
dated 24.2.98.

In accordance with the instructions of the Engineer in
Chief, W.R.O & Chief Engineer (General), Public Works Department,
Chennai in the reference 3rd and 4th cited, the name of
Thiru K. Kumarakurubaran, B.E., M.I.E., F.I.V., M.I.C.A.,
F.I.C.I., 10, J.K.K. Road, Near Head Post Office, B. Komara-
palayam, Tiruchengode Taluk, Namakkal District is included
in the panel of Private Practising Engineers under the
Category of Class-I in Namakkal District for the purpose of
issuing structural soundness certificate for Public Buildings
in Namakkal District under the purview of the Tamil Nadu Public
Buildings Licencing Act, 1965.


District Collector,
Namakkal.

To

Thiru K. Kumarakurubaran, B.E.,
10, J.K.K. Road,
Near Head Post Office,
B. Komarapalayam -638 183,
Tiruchengode Taluk.


12/11/99



PROCEEDINGS OF THE DISTRICT COLLECTOR, ERODE
PRESENT: THIRU T.UDHAYACHANDRAN, I.A.S.,

23/6/07

R.Dis. No. 25659/2007 C2

Dated: 21.6.2007

Sub: Tamil Nadu Public Buildings Licensing Act 1966 –
Panel of Private Practicing Engineers – Inclusion of the
name of Thiru K.Kumaraguruparan – In the Panel of
Private Practicing Engineer under Class I-A (One-A) –
Category in Erode District – Orders issued.

Ref: 1. Engineer-In-Chief, WRO & Chief Engineer
(General) P.W.D, Chennai Letter No.
AEE/T1/JE/38051/06 dated: 31.5.2007.
2. Board of Engineers Proceedings No. BOE-18
Dated: 30.5.2007.

ORDER:

Under the provisions of Rule 11 of the Tamil Nadu Public Buildings Licensing Rules 1966, the name of Thiru K.Kumaraguruparan, residing at 'K.K.A.K.Illam', 32 Sivagnanam Street, Opp. To Kamatchi Amman Kalyana Mandapam, Bhavani 638 301, Erode District is hereby included in the Panel of Registered Engineers under Class I-A (One-A) Category in Erode District for the purpose of issuing Structural Soundness Certificate of Public Buildings (Buildings cost which exceeds Rs.30 Lakhs (Rupees Thirty Lakhs and above) with reference to the Tamil Nadu Public Building Licensing Act 1965 and the Rules covered there under.

(Sd.)T.Udhayachandran.
District Collector,
Erode.

/True Copy/By Order/

B. S. [Signature]
22.6.07
For Collector.

To

1
Er. K.Kumaraguruparan,
K.K.A.K.Illam,
32 Sivagnanam Street,
Bhavani 638 301.

[Signature]
22.6.07

Copy to: Superintending Engineer (PWD) Building Division, Erode.

Copy to: Engineer-In-Chief WRO and Chief Engineer (General) PWD,
Chepauk, Chennai 600 005.

Copy to: The Sub Collector, Gobichettipalayam.

Copy to: Tahsildar, Bhavani.

Copy to: Stock File of C2/L5

